


**UPDATED**  
**NOTICE OF GROUNDWATER PROTECTION STANDARD EXCEEDANCE**  
**40 CFR §257.95(g)**  
**GRAND HAVEN BOARD OF LIGHT AND POWER**  
**J.B. SIMS GENERATING STATION**  
**FORMER 3 A/B IMPOUNDMENTS**

The following Appendix IV constituent(s) were detected at statistically significant levels above groundwater protection standards established during assessment monitoring pursuant to the “Disposal of Coal Combustion Residuals from Electric Utilities” Final Rule, 40 C.F.R. 257.95 (g) at Grand Haven Board of Light and Power, Former J.B. Sims Generating Station Former Unit 3 A/B Impoundments.

- Chromium
- Cobalt
- Fluoride
- Lithium

As described in the *Second Quarter 2021 Monitoring Report*, the monitoring well network is currently being evaluated and statistical evaluations may change significantly based on an updated monitoring well network as well as a revised background dataset. Therefore, the above mentioned statistically significant levels above groundwater protection standards are based on current statistical evaluations. Grand Haven Board of Light and Power will continue groundwater monitoring and reporting activities as required by 40 CFR §257.95.

**Golder Associates Inc.**

  
\_\_\_\_\_  
Carolyn E. Powrozek, C.P.G.      July 22, 2021  
Date  
*Senior Project Geologist*

  
\_\_\_\_\_  
Dawn L. Prell, C.P.G.      July 22, 2021  
Date  
*Senior Consultant*

[https://golderassociates.sharepoint.com/sites/27317g/deliverables/200 reports/2021 annual report/2q2021/updated notice/final ghblp unit 3 notice of gwps exceedance.docx](https://golderassociates.sharepoint.com/sites/27317g/deliverables/200%20reports/2021%20annual%20report/2q2021/updated%20notice/final%20ghblp%20unit%203%20notice%20of%20gwps%20exceedance.docx)